

5- High Voltage Test

- * A Ten meters sample should be immerced in water with it's Two ends out of water for One Hour
- * Apply 2500 Volt between One end of the sample and water for Five Minutes
- * The sample passes the test if there is no insulation break down

